


ACO Water Management		Page 1
ACO Business Park Hitchin Road Bedfordshire SG17 5TE	Canterbury	
Date 01/09/2019 File Canterbury 01-09-19.MDX	Designed by Dave Dunn Checked by	
Micro Drainage	Network 2019.1	

Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000      Additional Flow - % of Total Flow 0.000  
Hot Start (mins) 0      MADD Factor \* 10m<sup>3</sup>/ha Storage 2.000  
Hot Start Level (mm) 0      Inlet Coefficient 0.800  
Manhole Headloss Coeff (Global) 0.500      Flow per Person per Day (l/per/day) 0.000  
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0      Number of Storage Structures 7  
Number of Online Controls 1      Number of Time/Area Diagrams 0  
Number of Offline Controls 0      Number of Real Time Controls 0


Synthetic Rainfall Details

Rainfall Model      FSR      Ratio R 0.378  
Region England and Wales Cv (Summer) 0.750  
M5-60 (mm)      26.250 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm)      300.0  
Analysis Timestep 2.5 Second Increment (Extended)  
DTS Status      ON  
DVD Status      ON  
Inertia Status      OFF

Profile(s)      Summer and Winter  
Duration(s) (mins)      15, 30, 60, 120, 180, 240, 360, 480, 600,  
720, 960, 1440, 2160, 2880, 4320, 5760,  
7200, 8640, 10080  
Return Period(s) (years)      100  
Climate Change (%)      20

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.
1.000	1	15 Winter	100	+20%	100/15 Summer	100/15 Summer		
2.000	2	30 Winter	100	+20%	100/15 Summer			
3.000	3	30 Winter	100	+20%	100/15 Summer			
4.000	4	30 Winter	100	+20%	100/15 Summer			
5.000	5	15 Winter	100	+20%	100/15 Summer			
1.001	6	30 Winter	100	+20%	100/15 Summer			
6.000	7	1440 Winter	100	+20%	100/15 Summer			
7.000	8	1440 Winter	100	+20%	100/15 Summer			
8.000	9	15 Winter	100	+20%				
1.002	9	1440 Winter	100	+20%	100/15 Summer			
9.000	10	1440 Winter	100	+20%	100/15 Summer			
10.000	12	15 Winter	100	+20%	100/15 Summer			
9.001	11	1440 Winter	100	+20%	100/15 Winter			
11.000	12	1440 Winter	100	+20%	100/120 Winter			
12.000	15	15 Winter	100	+20%				
11.001	13	1440 Winter	100	+20%	100/60 Summer			
1.003	14	1440 Winter	100	+20%	100/15 Winter			
1.004	15	960 Winter	100	+20%	100/15 Summer			

ACO Water Management		Page 2
ACO Business Park Hitchin Road Bedfordshire SG17 5TE	Canterbury	
Date 01/09/2019 File Canterbury 01-09-19.MDX	Designed by Dave Dunn Checked by	
Micro Drainage	Network 2019.1	

Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m <sup>3</sup> )	Flow / Overflow Cap. (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	1	5.303	0.795	2.964	1.72	54.5	FLOOD	4
2.000	2	4.550	0.179	0.000	0.96	15.8	SURCHARGED	
3.000	3	4.563	0.134	0.000	0.90	14.3	SURCHARGED	
4.000	4	4.593	0.220	0.000	0.87	14.2	SURCHARGED	
5.000	5	4.794	0.427	0.000	1.56	21.3	SURCHARGED	
1.001	6	4.525	0.300	0.000	1.28	84.3	SURCHARGED	
6.000	7	4.370	0.231	0.000	0.10	1.3	SURCHARGED	
7.000	8	4.370	0.178	0.000	0.18	2.3	SURCHARGED	
8.000	9	4.952	-0.148	0.000	0.99	32.4	OK	
1.002	9	4.369	0.349	0.000	0.25	14.0	SURCHARGED	
9.000	10	4.369	0.149	0.000	0.06	1.9	SURCHARGED	
10.000	12	5.175	0.075	0.000	1.72	25.8	FLOOD RISK*	
9.001	11	4.369	0.349	0.000	0.07	3.5	SURCHARGED	
11.000	12	4.369	0.157	0.000	0.05	3.5	SURCHARGED	
12.000	15	5.046	-0.054	0.000	1.23	51.4	FLOOD RISK*	
11.001	13	4.369	0.274	0.000	0.07	3.9	SURCHARGED	
1.003	14	4.369	0.369	0.000	0.11	6.2	SURCHARGED	
1.004	15	4.380	0.424	0.000	0.04	3.7	SURCHARGED	