



Our Ref: EMC/2017/192

Date: 19th June 2018

Attention Maria Short
Canterbury City Council
Council Offices
Military Road
Canterbury
Kent, CT1 1YW

By Email Only

Dear Maria

**Residential Development at Havelock Street, Canterbury, Kent
CA/18/00260 ~ Discharge of Condition 6**

We refer to the correspondence received from Southern Water under cover of their letter dated 29th May 2018 with regard to consultation on the discharge of the above condition.

As requested, we attended site on the 13th June 2019 and carried out sewer tracing using drain dye to confirm the connectivity of the existing road gullies that receive the existing surface water run-off from the pre-developed site as discussed within the Drainage Impact Assessment.

Attached are photographs taken during the investigations and demonstrates connectivity to TR15582001.

We trust that the above and enclosed meets with your approval, should you require any further clarification please do not hesitate to contact us.

Yours sincerely

Paul Lavender





Frame 1 ~ Road Gullies at the end of Old Ruttington Lane looking towards Broad Street



Frame 2 ~ Gully Frame lifted and bucket of water with fluorescent drain dye seen in background ready to pour in the gully



Frame 2 ~ Cover to TR15582001 removed under traffic control



Frame 4 ~ Drain Dye emerging at TR15582001